

Addendum #1

for:

Richland County Recreation Commission North Springs and Polo Road Recreation Center Roof Replacements

Issue Date December 23, 2025

- 1) The following items add to, modify, clarify, or otherwise alter the Drawings and/ or specifications and will be a part of the Contract Documents. Where a portion of the Drawings and/or specification is added to, modified, or otherwise altered, the portion not so affected shall remain. Bidder shall include all effects that these items may have on this proposal.
- 2) The base layer of polyisocyanurate insulation at the Polo Road Recreation Center does not need to be bevel cut. Insulation should be factory cut to fit between the standing seam ribs without gaps.

END OF ADDENDUM #1